

Prepared For:
 Becky Tipton
 708 S. Nineth
 Poplar Bluff, Mo 63901

Conducted By:
 Aire Serv Heating & Air
 Conditioning
 573-778-9007

Test Period:
 9/21/06 – 9/27/06

Monitor ID:
 #7049

Report ID:
 #66524

This report offers recommendations so you can make informed decisions about your family's health, comfort and safety. Knowing what's in the air you breathe and what you can do about it has never been more important. If you have additional questions, visit www.airadvice.com or call 503-295-6610.


What We Tested

What We Found

Possible Causes

Recommended Action

HEALTH



Action Necessary


Particle Allergens, Chemical Pollutants

- ▶ **Particle Allergens:**
Levels are significantly elevated
- ▶ **Chemical Pollutants:**
Levels improvable

- Inadequate filtration
- Build-up of chemical pollutants

- Add VOC reduction device
- Remove VOC sources
- Upgrade filtration

COMFORT



Action Necessary


Temperature Relative Humidity

- ▶ **Temperature:**
Somewhat too cool
- ▶ **Relative Humidity:**
Too moist

- Inadequate temperature setpoint or inadequate thermostat
- Inadequate dehumidification

- Check thermostat for proper setpoint and function
- Upgrade dehumidification equipment
- Add ventilation

SAFETY



Action Necessary

Carbon Monoxide

- ▶ **Carbon Monoxide:**
Levels significantly elevated

- Carbon monoxide source in home or garage

- Remove carbon monoxide source in home or garage

